UT24 | united technologies 24
fire alarms • access control • security systems • cctv

BAFE FIRE SAFETY REGISTER
Fire Alarm System Service Provider

FIRE DETECTION & FIRE ALARM SYSTEM ACCEPTANCE CERTIFICATE (BS5839-1:2025)

Certificate of ACCEPTANCE for the fire detection and fire alarm system at:

Site Address:

I/we being the competent person(s) responsible (as indicated by my/our signature below) for acceptance of the fire detection and fire alarm system, particulars of which are set out below, ACCEPT the system on behalf of:

Name: Signature: Date:

For and behalf of:

The extent of liability of the signatory is limited to the system described below.

Extent of installation work covered by this certificate:

☐ All installation work appears to be satisfactory.

☐ The system is capable of giving a fire alarm signal.

☐ The facility for remote transmission of alarms to an alarm receiving centre operates correctly. (Delete if not applicable).

☐ A suitable zone plant (or other suitable diagrammatic representation) of the premises is provided on or adjacent to all control and indicating equipment. (Delete if not applicable).

Correspondence Address: United Technologies 24 Ltd, Horizon House, Sittingbourne Road, Maidstone, Kent, ME14 3EN
Telephone: 01233 713780 E-mail: Sharon.demery@united24.co.uk E-mail: Paul.marsh@united24.co.uk www.united24.co.uk
Registered Office: c/o Skyfire Accountancy Ltd, The Old Rectory, Springhead Road, Northfleet, Kent, DA11 8HN

UT24 | united technologies 24
fire alarms • access control • security systems • cctv

BAFE FIRE SAFETY REGISTER
Fire Alarm System Service Provider

FIRE DETECTION & FIRE ALARM SYSTEM ACCEPTANCE CERTIFICATE (BS5839-1:2025)

The following documents have been provided to the purchaser or user:

- ☐ As-fitted drawings.
- ☐ Operating and maintenance instructions.
- ☐ Certificates of installation and commissioning.
- ☐ A fire alarm log book.
- ☐ Electrical installation certificate in accordance with BS 7671 for the supply to all mains related wiring.
- ☐ Sufficient representatives of the user have bene properly instructed in the use of the system, including, at least, all means of triggering fire signals, silencing and resetting the system and avoidance of false alarms.

The following work is required before the system can be accepted:

Correspondence Address: United Technologies 24 Ltd, Horizon House, Sittingbourne Road, Maidstone, Kent, ME14 3EN
Telephone: 01233 713780 E-mail: Sharon.demery@united24.co.uk E-mail: Paul.marsh@united24.co.uk www.united24.co.uk
Registered Office: c/o Skyfire Accountancy Ltd, The Old Rectory, Springhead Road, Northfleet, Kent, DA11 8HN