UT24 | united technologies 24
fire alarms • access control • security systems • cctv

BAFE FIRE SAFETY REGISTER
Fire Alarm System Service Provider

FIRE DETECTION & FIRE ALARM SYSTEM COMMISSIONING CERTIFICATE (BS5839-1:2025)

Site Address:

I/we being the competent person(s) responsible (as indicated by my/our signature below) for the commissioning of the fire detection and fire alarm system, particulars of which are set out below, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of BS5839-1:2025, Clause 37, except for the variations, if any, stated in this certificate.

Commissioning Signatory:

Name: **Position:**

Signature: **Date:**

For and on behalf of: **United Technologies 24 Ltd**

Address: **Horizon House, Sittingbourne Road, Maidstone, Kent, ME14 3EN**

The extent of liability of the signatory is limited to the systems described below.

Scope and Variations:

Extent of system covered by this certificate:

Variations from the recommendations of BS 5839-1:2025, Clause 37 (See BS 5839-1:2025, Clause 6).

UT24 | united technologies 24
fire alarms • access control • security systems • cctv

BAFE FIRE SAFETY REGISTER
Fire Alarm System Service Provider

FIRE DETECTION & FIRE ALARM SYSTEM COMMISSIONING CERTIFICATE (BS5839-1:2025)

Commissioning Confirmations:

- ☐ All equipment operates correctly.
- ☐ Installation work is, as far as can reasonable be ascertained, of an acceptable standard.
- ☐ The entire system has been inspected and tested in accordance with the recommendations of BS 5839-1:2025, 37.4.
- ☐ The system performs as required by the specification prepared by:
  A copy of which I/we have been given.
- ☐ Taking into account the guidance contained in BS 5839-1:2025, Section 3, I/we have not identified any obvious potential for an unacceptable rate of false alarms.
- ☐ The documentation described in BS 5839-1:2025, Clause 38, has been provided to the user.

Outstanding Work / Considerations:

The following work should be completed before/after (as specified below) the system becomes operational:

The following potential causes of false alarms should be considered at the time of the next service visit:

Soak Test (per BS 5839-1:2025, 33.5):

Before the system becomes operational, it should be soak tested in accordance with the recommendations of BS 5839-1:2025, 33.5, for a period of: 14 days.

Correspondence Address: United Technologies 24 Ltd, Horizon House, Sittingbourne Road, Maidstone, Kent, ME14 3EN
Telephone: 01233 713780 E-mail: Sharon.demery@united24.co.uk E-mail: Paul.marsh@united24.co.uk www.united24.co.uk
Registered Office: c/o Skyfire Accountancy Ltd, The Old Rectory, Springhead Road, Northfleet, Kent, DA11 8HN