UT24 | united technologies 24
fire alarms • access control • security systems • cctv

BAFE FIRE SAFETY REGISTER
Fire Alarm System Service Provider

PPM Servicing Certificate

Certificate of SERVICING for the fire detection and fire alarm system at**:**

I/we being the competent person(s) responsible (as indicated by my/our signature below) for the servicing of the fire detection and fire alarm system, particulars of which are set out below, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 45 of BS 5839-1:2025 planned preventative maintenance of annual inspection and test/inspection over a 12-month period including two planned preventative maintenance visits, except for the variations, if any, stated in this certificate.

Name: Signature: **Date:**

For and on behalf of: **United Technologies 24 Ltd**
Address: **Horizon House, Sittingbourne Road, Maidstone, Kent, ME14 3EN**

The extent of liability of the signatory is limited to the systems described below.

Extent of the system covered by this certificate:

Variations from the recommendations of Clause 45 of BS5839-1:2025 for periodic or annual inspection and test (as applicable):

☑ Relevant details of the work carried out and faults identified have been entered in the system log book.

During the past 12-months, …. false alarms have occurred - **Information not available from client.**

The above number of false alarms equates to … false alarms per 100 automatic fire detectors per annum (for Category M systems enter 'Not Applicable').

The following work/action is considered necessary: