



Commissioning Certificate for Fire Alarm System - COMMISSIONING

Certificate of Commissioning for the fire detection and fire alarm system at:

I/we being the competent person(s) responsible (as indicated by my/our signature below) for the commissioning of the fire detection and fire alarm system, particulars of which are set out below, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 39 of BS 5839-1:2017, except for the variations, if any, stated in this certificate.

Name: **Paul Marsh** Position: Signature: Date:

For and on behalf of: **United Technologies 24 Ltd**
 Address: **Springfield House, Sandling Road, Maidstone, Kent, ME14 2LP**

The extent of liability of the signatory is limited to the systems described below.

Extent of the system covered by this certificate:

.....

Variations from the recommendations of Clause 39 of BS 5839-1:2017 (see BS 5839-1:2017, Clause 7):

.....

- All equipment operates correctly.
- Installation work is, as far as can reasonably be ascertained, of an acceptable standard.
- The entire system has been inspected and tested in accordance with the recommendations of 39.2c of BS 5839-1:2017. .
- The system performs as required by the specification prepared by: a copy of which I/we have been given.
- Taking into account the guidance contained in Section 3 of BS 5839-1:2017, I/we have not identified any obvious potential for an unacceptable rate of false alarms.
- The documentation described in Clause 50 of BS 5839-1:2017 has been provided to the user.

The following work should be completed before/after (delete as applicable) the system becomes operational:

The following potential cause of false alarms should be considered at the time of the next service visit:

.....
.....

Before the system becomes operational, it should be soak tested in accordance with the recommendations of 35.2.6 of BS 5839-1:2017 for a period of: (enter a period of either one week, such period as required by the specification, or such period as recommended by the signatory to this certificate, whichever is the greatest, or delete if not applicable).

Correspondence Address: United Technologies 24 Ltd, Springfield House, Sandling Road, Maidstone, Kent, ME14 2LP

Telephone: 01233 713780

E-mail: Paul.marsh@united24.co.uk Sharon.demery@united24.co.uk E-mail: Sales@united24.co.uk

www.united24.co.uk

Registered Office: Suite 3, Falcon Court Business Centre, College Road, Maidstone, Kent, ME15 6TF